




УНИВЕРСИТЕТ ИТМО

# New thermal comfort indices based on iso-comfort arrays


Sulin A.B., Ryabova T.V., Sankina I.N., Nikitin A.A., Muraveinikov S.S.

2021

# Thermal Comfort Indices by P.O. Fanger





P.O. Fanger



# Radiative factor of thermal comfort



Globe thermometer




CFD modeling

# Mean radiative temperature

New factors:

- mean radiative temperature difference
- globe thermometer temperature difference



$$\bar{t}_r = \left[ (t_g + 273)^4 + \frac{1,1 \cdot 10^8 \cdot v_a^{0,6}}{\varepsilon D^{0,4}} \cdot (t_g - t_a) \right]^{\frac{1}{4}} - 273.$$

Mean radiative temperature difference  
vs  
globe thermometer's temperature difference

$$\Delta t_r = t_r - t_a$$

$$\Delta t_g = t_g - t_a$$

# Formation of iso-comfort arrays

**PMV = +0.49**

$\Delta t_r, ^\circ C$	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-8	27.60	27.63	29.27	27.65
-4	25.81	26.29	28.10	26.63
0	23.98	24.92	26.90	25.59
4	22.12	23.52	25.67	24.51
8	20.356	22.08	22.901	23.41

**PMV = -0.49**


$\Delta t_r, ^\circ C$	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-8	23.23	23.72	23.94	24.066
-4	21.45	22.40	22.81	23.06
0	19.63	21.04	21.65	22.03
4	17.89	19.65	20.46	20.07

Comfort class: B

Activity: 1.1 met

Clothes: 1.0 clo

# Iso-comfort arrays data base



PMV = -0.49 PPD=10% 0.7 clo Y=50%  
1.4 met 83 Br/m<sup>2</sup>

Δтрав., °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-4	27.7	28.2	28.4	28.6
-2	26.8	27.5	27.8	28.0
0	25.9	26.8	27.2	27.5
2	24.9	26.1	26.6	27.0
4	24.0	25.4	26.0	26.4

PMV = -0.49 PPD=10% 0.7 clo Y=50%  
1.3 met 76 Br/m<sup>2</sup>

Δтрав., °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-4	27.7	28.2	28.4	28.6
-2	26.8	27.5	27.8	28.0
0	25.9	26.8	27.2	27.5
2	24.9	26.1	26.6	27.0
4	24.0	25.4	26.0	26.4

PMV = -0.49 PPD=10% 0.7 clo Y=50%  
1.2 met 68 Br/m<sup>2</sup>

Δтрав., °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-4	27.7	28.2	28.4	28.6
-2	26.8	27.5	27.8	28.0
0	25.9	26.8	27.2	27.5
2	24.9	26.1	26.6	27.0
4	24.0	25.4	26.0	26.4

PMV = -0.49 PPD=10% 0.7 clo Y=50%  
1.1 met 64 Br/m<sup>2</sup>

Δтрав., °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-4	27.7	28.2	28.4	28.6
-2	26.8	27.5	27.8	28.0
0	25.9	26.8	27.2	27.5
2	24.9	26.1	26.6	27.0
4	24.0	25.4	26.0	26.4

M = 1.1; 1.2; 1.3; 1.4 met

# Equivalent comfort temperature

Equivalent temperature by Madsen T. L. (ASHRAE trans. - 1984. - T. 90):

$$t_{eq} = 0.55 * t_a + 0.45 * \bar{t}_r + \frac{0.24 - 0.75\sqrt{v_a}}{1 + I_{cl}} (36.5 - t_a)$$

New index: *equivalent comfort temperature*:

$$t_{eqc} = 0.55 * t_{ac} + 0.45 * \bar{t}_{rc} + \frac{0.24 - 0.75\sqrt{v_{ac}}}{1 + I_{cl}} (36.5 - t_{ac})$$

# Equivalent comfort temperature data base

Comfort class: B Activity: 1.1 met Clothes: 1.0 clo

## Calculation example

PMV = +0.49				
$\Delta t_r$ , °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-8	24.5	24.1	23.7	23.4
-4	24.5	24.2	23.9	23.7
0	24.4	24.4	24.2	23.9
4	24.4	24.5	24.5	24.2
8	24.4	24.6	24.6	24.4
Mean value 24.2		Deviation 0.3		

PMV = -0.49				
$\Delta t_r$ , °C	v = 0.1, m/s	v = 0.3, m/s	v = 0.5, m/s	v = 0.7, m/s
-8	20.4	20.1	19.8	19.4
-4	20.4	20.3	20.0	19.7
0	20.4	20.5	20.2	20.0
4	20.4	20.6	20.5	20.2
8	20.4	20.7	20.7	20.5

PMV = + 0.49			
	0.7 clo	1.0 clo	1.3 clo
<b>1.1 met</b>	25.7	24.2	22.8
<b>1.2 met</b>	25.3	23.8	22.3
<b>1.3 met</b>	24.5	22.9	21.3
<b>1.4 met</b>	23.8	22.1	20.4
PMV = - 0.49			
	0.7 clo	1.0 clo	1.3 clo
<b>1.1 met</b>	22.7	20.3	18.2
<b>1.2 met</b>	21.8	19.5	17.3
<b>1.3 met</b>	20.5	18.0	15.6
<b>1.4 met</b>	19.4	16.8	14.2

Comfort class: B  
Summarized data

# Equivalent comfort temperature calculation

## (RU Patent No 2682872)

Comfort class ISO 7730	Thermal sensation PMV	Equivalent comfort temperature
A	+0.19	$t_{eqc} = 47.69 * 0.67^{met} * 0.76^{clo}$
	-0.19	$t_{eqc} = 56.10 * 0.58^{met} * 0.70^{clo}$
B	+0.49	$t_{eqc} = 43.23 * 0.73^{met} * 0.80^{clo}$
	-0.49	$t_{eqc} = 66.49 * 0.51^{met} * 0.65^{clo}$
C	+0.69	$t_{eqc} = 40.69 * 0.77^{met} * 0.82^{clo}$
	-0.69	$t_{eqc} = 72.58 * 0.47^{met} * 0.62^{clo}$

# Index:

## Operative (*resulting, effective*) comfort temperature


	0.1	0.2	0.3	0.4	0.5	Iso-comfort array
-6	<b>18.47</b>	<b>18.95</b>	<b>19.29</b>	<b>19.46</b>	<b>19.65</b>	
-4	<b>17.60</b>	<b>18.25</b>	<b>18.61</b>	<b>18.88</b>	<b>19.07</b>	
-2	<b>16.69</b>	<b>17.51</b>	<b>17.98</b>	<b>18.30</b>	<b>18.54</b>	
0	<b>15.78</b>	<b>16.74</b>	<b>17.30</b>	<b>17.66</b>	<b>17.94</b>	
2	<b>14.95</b>	<b>16.01</b>	<b>16.65</b>	<b>17.07</b>	<b>17.41</b>	
4	<b>14.11</b>	<b>15.25</b>	<b>15.98</b>	<b>16.46</b>	<b>16.82</b>	
6	<b>13.34</b>	<b>14.50</b>	<b>15.26</b>	<b>15.81</b>	<b>16.21</b>	
	0.1	0.2	0.3	0.4	0.5	
-6	15.77	16.61	17.19	17.54	17.85	Operative comfort temperature
-4	15.8	16.69	17.21	17.60	17.87	
-2	15.79	16.73	17.28	17.66	17.94	
0	15.78	16.74	17.30	17.66	17.94	
2	15.85	16.79	17.35	17.71	18.01	
4	15.91	16.81	17.38	17.74	18.02	
6	16.04	16.84	17.36	17.73	18.01	
Mean value	15.84857	16.74429	17.29571	17.66286	17.94857	
Deviation	0.097541	0.078285	0.07413	0.072736	0.069144	
Weight ratio for $t_a$	<b>0.55</b>	<b>0.61</b>	<b>0.65</b>	<b>0.68</b>	<b>0.7</b>	
Weight ratio for $t_r$	<b>0.45</b>	<b>0.39</b>	<b>0.35</b>	<b>0.32</b>	<b>0.3</b>	

New index

$$t^*_o = k_a \cdot t_a + (1 - k_a) \cdot t_r$$

$$k_a = -0.64 \cdot v^2 + 0.76 \cdot v + 0.48$$

# New operative temperature wight ratio



# Operative temperature: 3 calculate methods

## ANSI/ASHRAE Standard 55

$$t_o = \frac{t_r + t_a \cdot \sqrt{10v}}{1 + \sqrt{10v}}$$


## GOST 30494-2011

$$t_o = \frac{t_a + t_r}{2} \text{ for } v \leq 0.2$$



$$t_o = 0.6t_a + 0.4t_r$$

## New index

$$t_o^* = (-0.64v^2 + 0.76v + 0.48) \cdot t_a + (0.64v^2 - 0.76v + 0.52) \cdot t_r$$



# Predicted mean vote of thermal comfort based on operative comfort temperature ( $ta = +23^{\circ}\text{C}$ )



# Conclusions

1. New concepts have been introduced:

- isocomfortable parameters matrix;
- equivalent comfort temperature;
- radiation temperature difference;
- the temperature difference of the ball thermometer;
- operational (resulting) comfortable temperature.

2. Generalized calculated expressions for the premises microclimate parameters of three comfort classes according to ISO 7730 have been obtained and patented.

3. New weighting factors were obtained for determining the operating temperature based on the method of P.O. Fanger.

4. It is shown that the use of a new method for calculating the operating temperature leads to an increase in the expected thermal comfort level in the room.



УНИВЕРСИТЕТ ИТМО

# Thank you for attention

Sankina Iuliia  
ulyashka95@yandex.ru